

REFERENCE MAP

Site Development Plan, Nicholas Kharoush, Lots 1-4,
Goose Lane / Goose Lane, Guilford, Conn. Scale 1"=40',
Date 1/23/97, by Bonaiuto / Lanphier Design Group

SOIL TEST RESULTS

per Site Development Plan

1-1
0-9" Topsoil
9-24" Brown f-sand, some sil. w/cobbles & boulders
24-54" Brown f-m sand, tr. sil, w/ boulders & cobbles (medium compact)
Refusal @ 54", Water @ 39"
Perc Rate 13 min./in (by R. Waldo 12/16/98)

1-2
0-12" Topsoil
12-36" Brown f-sand, and sil, w/cobbles & boulders
36-72" Brown f-c sand, and c-f gravel (wet/loose)
Water @ 38"

by R.W. Waldo 1/13/99

1A
0-6" Topsoil
6-30" Sandy loam
30-64" Sand and gravel
Ledge @ 36" N. and, 64" S. and Mottling @ 24", Water @ 54"
Perc Rate 20 min./in.

1B
0-6" Topsoil
6-40" Sandy loam
40-84" Sand and gravel
Mottling @ 24", Water @ 72"

by R.W. Waldo 07/01/99
2C
0-18" Topsoil and fill
18-30 sandy loam
30-38" Fine sandy loam
38-72" sand and gravel
Mottling @ 30" Ledge @ 72"

2D
0-26" Fine sandy loam
26-72" Sand and gravel
Ledge @ 72"

DESIGN CALCULATIONS

4 Bedroom, 10.1-20 min./in
900 g.f. Required
138 l.f. @ 9 s.f./l.f. = 1038 s.f. Provided
100% Reserve Provided

MLSS

Slope = 4 -6% Depth = 30" (DTP 6C)
HF=30, FF=2.0, PF=1.5
MLSS=30x(2)1.5=90"
System Sized Provided = 90"



1250 Gal. Septic Tank



12" LOW PROFILE LEACHING CHAMB

130



REFERENCE MAP

Site Development Plan, Nicholson Khoroomi, Lots 1-4,
Goose Lane / Goose Lane, Guilford, Conn. Scale 1"=40',
Date 1/23/97, by Barabas / Lanuto Design Group

SOIL TEST RESULTS

per Site Development Plan

4-1
0-6" Topsoil
6-24" Brown f-m sand, some s/l, w/cobbles & boulders
24-54" Brown f-m sand, tr s/l, w/ boulders & cobbles (medium compact)
Refusal @ 54", Water @ 39"
Perc Rate .13 min./in (by R. Waldo 12/16/98)

4-2
0-12" Topsoil
12-36" Brown f-sand, and s/l, w/cobbles & boulders
36-72" Brown f-c sand, and c-f gravel (wet/loose)
Water @ 38"

by R.W. Waldo 1/13/99

5A
0-6" Topsoil
6-30" Sandy loam
30-84" Sand and gravel
Ledge @ 36" N. and, 64" S. and, Mottling @ 24", Water @ 54"
Perc Rate 20 min./in.

5B
0-6" Topsoil
6-40" Sandy loam
40-84" Sand and gravel
Mottling @ 24", Water @ 72"

by R.W. Waldo 07/01/99

6A
0-18" Topsoil and fill
18-30 sandy loam
30-38" Firm sandy loam
38-72" sand and gravel
Mottling @ 30"; Ledge @ 72'

6D
0-24" Fine sandy loam
24-72" Sand and gravel
Ledge @ 72'

DESIGN CALCULATIONS

4 Bedroom: 10.1-20 min./in
900 g.f. Required
176 l.f. @ 9 s.f./l.f. = 1038 s.f. Provided
100% Reserve Provided

MLSS

Slope = 4-6% Depth = 30" (DTP 6C)
HF=30, FF=2.0, PF=1.5
MLSS=30x1.5x1.5=90"
System Sized Provided = 90"

1250 Gal. Septic Tank

12" LOW PROFILE LEACHING CHAMB

130