



Addendum

Project Number: 10-1718 Addendum Number: 1
Project Name: Guilford Elevator and Fire Alarm Upgrades
Date: March 21, 2018

This Addendum is an integral part of the Contract Documents and shall be treated as such. Bidders shall acknowledge receipt of this Addendum on the Bid Form. The following changes shall supersede previously issued Contract Documents to the extent modified by this Addendum.

RFI Response:

- 1. Q: It appears that Panel BPP is not located in storage room 019 as shown of the prints, but in mechanical room 013. Should the EC cover the associated costs of the longer feeder run in the bid?**
A: Contractor to provide cost to run wiring and conduit to actual location of panel in Room 013.
- 2. Q: Attic Heat detectors are shown as Cold Temperature. Please confirm this correct?**
A: Yes, the heat detectors are to be rated for cold temperatures within attic.
- 3. Q: Will Fire Alarm Cable be required to be installed in conduit when above a hung ceiling?**
A: Cable above ceiling or within walls does not required conduit.
- 4. Q: Does this include modernization of the elevator as well?**
A: The scope of the project includes elevator control, and electrical upgrades in addition to a new ladder. See drawings for details.

Bid opening remains Tuesday March 27th at 2pm.

End of Addendum