



Addendum

Project Number: #8-1718 Addendum Number: 3
Project Name: Cox and Baldwin School Electrical Upgrades
Date: March 19, 2018

This Addendum is an integral part of the Contract Documents and shall be treated as such. Bidders shall acknowledge receipt of this Addendum on the Bid Form. The following changes shall supersede previously issued Contract Documents to the extent modified by this Addendum.

1) Cox School: Main Switch Gear Room:

- a. **New switch gear is to be installed in location of existing switch gear.**
- b. **Remove existing concrete step at entrance and replace with new concrete step at right hand side of door. This is to allow clearance in front of switch gear.**
- c. **Reconfigure door hardware to coordinate with new step location. Existing door to remain.**

2) Baldwin School:

- a. **Drawing E1.00, Remove Key Note E. Existing Wall to remain.**
- b. **Drawing E1.00, Key Note F to be revised, delete last sentence "Exterior door to be removed and wall to be sealed up with block" The intent is for the exterior door to remain, and the new switch gear to be installed within utility vault.**
- c. **The contractor is coordinate the installation of the new switch gear with the removal of the existing transformer by the utility company.**
- d. **The bid opening date is moved to March 26th, 2018 at 2pm.**

End of Addendum